

TEHAMA COUNTY FIRE DEPARTMENT

Fire Protection Planning Bureau
633 Washington St. Room 22., Red Bluff, California 96080,

(530) 527-7986



Residential Fire-flow is required for all new single family dwellings over 3500 sq. ft.

Fire-flow is considered
4000 gallons of available stored water.
Private fire service connection – 2 ½ inch
20 psi
200 gal per min. for 20 min.
There may be additional requirements.

If you have questions about what is required in Tehama County please give us a call. (530) 527-7986